

Testing Authority
CSIRO Infrastructure Technologies
14 Julius Avenue, North Ryde NSW 2113
PO Box 310, North Ryde NSW 1670, Australia
T (02) 9490 5444 • ABN 41 687 119 230

Certificate of Assessment

Certificate Of Assessment Number	Certificate Issue Date	Certificate Validity Date	Page
COA 3286 Revision A	23/10/2023	31/10/2028	1 of 1

Referenced Assessment	Test Standard	Proprietary Name(s)	Report Sponsor
FCO-3286 Revision A Short Form	AS1530.4-2014	Forster Fuego Light steel frame Pilkington Pyrostop® DGU glazing systems	Technical Protection Systems Pty Ltd 2/21 Malvern Street, BAYSWATER VIC 3153

Introduction

The Element of construction below was assessed by this laboratory on behalf of the report sponsor in accordance with the stated test standard and achieved the results stated below. Refer to the referenced assessment report for a full description of the assessed construction and performance claims.

Product Details & Performance Outcome(s)

Glazing	Frame	Pane size (mm)	FRL
23mm Pyrostop / 6mm gap / 23mm Pyrostop	Forster Fuego Light 110mm x 50mm fully filled frame tubes	Max area - 3.40m ² Max height - 2400mm Max width - 2400mm	-/120/120
23mm Pyrostop / 6mm gap / 27mm Pyrostop			
23mm Pyrostop/ 6mm gap / 18mm Pyrostop	Forster Fuego Light 110mm x 50mm	Max area - 3.74m ² Max height - 2830mm Max width - 2830mm	-/90/90

Refer to the referenced assessment report for a full description of the assessed construction and performance claims.

Limitations

- This Certificate provides summary information only and does not comply the regulatory requirements for evidence of compliance.
- The referenced assessment report provides full details of the tested system, the results, observations, conclusions limitations and validity of test. This relevant assessment report should be viewed for the purposes for evidence of compliance.
- The test results relate to only the behaviour of the specimen under the particular conditions of test; they are not intended to provide a full assessment of fire hazard under all fire conditions.

Author	Reviewed By	Authorised
Keith Nicholls	Jing Xu	Keith Nicholls
		
23/10/2023	23/10/2023	23/10/2023