



Fire Test Certificate

This is to certify that the specimen described below has been examined by BRANZ Ltd on behalf of

Pacific Door Systems Limited
17 Meachen Street
Seaview
Lower Hutt, 5010
New Zealand

Test standard: AS 1530.4:2014

Specimen name: Armashield-FR and SPS1-FR doorsets

Specimen description:

Armashield FR Doorset	FRR
Leaf size up to a maximum 2,700 mm high x 1,200 mm wide	-/90/-
Grout filled security bars	-/90/-
6 mm Pyran S glazing: <ul style="list-style-type: none">Up to a maximum size of 1,200 mm high x 900 mm wide;Multiple vision panels with a maximum combined area not exceeding 2.16 m².	-/90/-
44 mm NOVOLAY Secure BR4 NS/1.5.4: <ul style="list-style-type: none">Up to a maximum size of 700 mm high x 600 mm wide;Multiple vision panels with a maximum combined area not exceeding 0.84 m².Weight not to exceed 44 kg/hinge.	-/60/-
SPS1-FR doorset	FRR
Leaf size up to a maximum 2,350 mm high x 1,150 mm wide	-/60/60
Grout filled security bars	-/60/-
6 mm Pyran S glazing: <ul style="list-style-type: none">Up to a maximum size of 1,000 mm high x 850 mm wide;Multiple vision panels with a maximum combined area not exceeding 1.7 m².	-/60/-
44 mm NOVOLAY Secure BR4 NS/1.5.4: <ul style="list-style-type: none">Up to a maximum size of 700 mm high x 600 mm wide;Multiple vision panels with a maximum combined area not exceeding 0.84 m².Weight not to exceed 36 kg/hinge.	-/60/-

Orientation: Fire exposure from either side.

A full description of the test specimen and the test results are given in BRANZ Test Reports and Assessments:

BRANZ Fire Assessment Report FC14150-01-2

Conditions of laboratory registration by IANZ do not allow assessments by the Registered Laboratory to be covered by IANZ.

Regulatory authorities are advised to examine test reports before approving any product.

Certificate issued: 10 March 2023

Certificate Number: FC14150-01-C1-2

P. Chapman
Senior Fire Testing Engineer
For BRANZ Limited



This Laboratory is accredited by International Accreditation New Zealand (IANZ). The tests reported herein have been performed in accordance with the laboratory's scope of accreditation.

The National Association of Testing Authorities (NATA) and International Accreditation New Zealand (IANZ) are both signatories of the ILAC Mutual Recognition Agreement.

The following statement is required by the test standard "This certificate is provided for general information only and does not comply with the regulatory requirements for evidence of compliance."